


**FCI® FLUID COMPONENTS
INTERNATIONAL LLC**

Supplemental Manual

ST80 Series Safety Instrumented System (SIS) Requirements

ST80 Series Thermal Mass Flow Meter

Models: ST80, ST80L



Notice of Proprietary Rights

This document contains confidential technical data, including trade secrets and proprietary information which is the property of Fluid Components International LLC (FCI). Disclosure of this data to you is expressly conditioned upon your assent that its use is limited to use within your company only (and does not include manufacture or processing uses). Any other use is strictly prohibited without the prior written consent of FCI.

© Copyright 2020 by Fluid Components International LLC. All rights reserved. FCI is a registered trademark of Fluid Components International LLC. Information subject to change without notice.

Table of Contents

Table of Contents.....	iii
List of Tables.....	iii
ST80 Series Safety Instrumented System (SIS) Requirements	1
Introduction	1
Compliance Through FMEDA (Failure Modes, Effects And Diagnostic Analysis)	1
ST80 Safety Identification	1
Installation in SIS Applications	1
Configuring the Instrument for SIS Application	1
Proof Test.....	2
Recommended Proof Test	2
Calculation of Average Probability Of Failure On Demand (PFD _{avg}).....	2
Product Repair	2
ST80 Series SIS Reference	2
Failure Rate Data	2
Terminology	2
Proof Test Coverage	3

List of Tables

Table 1 – Failure Rates with Good Maintenance Assumptions in FIT @ SSI=2 According to IEC 61508.....	2
Table 2 – Total Coverage (Proof Test DD + Internal Diagnostics DD)	3

This Page Intentionally Left Blank

ST80 Series Safety Instrumented System (SIS) Requirements

Introduction

This document describes how to configure the ST80 Series for IEC 61508 compliance in a Safety Instrumented System (SIS) application. The safety-critical output of the ST80 Series is provided through the Channel #1 HART output or Channel #2 analog output.

Compliance Through FMEDA (Failure Modes, Effects And Diagnostic Analysis)

Safety Integrity Level, Hardware Fault Tolerance:

- SIL 1, HFT = 0
- SIL 2, HFT = 1
- SIL 3, HFT = 2

Subsystem Type:

- B

ST80 Safety Identification

Verify that the ST80 Series system firmware is v1.07L or higher. The firmware version can be identified via the HMI (models with Display) during instrument boot-up, the ST80 configuration software, or by contacting FCI directly to cross reference the unit's serial number with its firmware version as shipped. The information in this document relates to all ST80 Series flow meter configurations.

Installation in SIS Applications

Installations are to be performed by qualified personnel. No special installation is required in addition to the standard installation practices outlined in the ST80 Series IO&M (Document No. 06EN003490). Environmental and operational limits are listed in the manual's Technical Specifications section.

Configuring the Instrument for SIS Application

For all safety-related applications, configure the ST80 Series flow meter in a fail-safe alarm configuration as listed below.

- Verify that materials are compatible with process conditions.
- Configure the device for fault indication per NAMUR NE43 OR the logic solver is configured to interpret 4 mA as a fault condition.
 - Low Alarm current is ≤ 3.6 mA
 - High Alarm current is ≥ 21.0 mA
 - Channel #1 4-20 mA analog output is configured for Flow
- The safety accuracy of the ST80 Series mass flow output is $\pm 2.0\%$ of reading and $\pm 0.5\%$ of full scale. Base accuracy is dependent on the process gas composition, pressure and temperature. These parameters can be found in the appropriate calibration certificate. Contact FCI if you would like to obtain a copy referenced by the unit's serial number.
- Use the password protection feature of the ST80 firmware to prevent accidental or deliberate change of process parameters and configuration data during normal operation.
- HART protocol is only used for setup, calibration, and diagnostic purposes; not for safety critical operation.

Proof Test

Use the recommended proof test described below to identify Dangerous Undetected failures in the ST80 Series thermal mass flow meter. This test consists of cycling the power, setting the output to minimum and maximum values and a calibration check. It is recommended that the proof test be performed annually at a minimum.

Recommended Proof Test

1. Bypass the safety function and take appropriate action to avoid a false trip.
2. Use digital communications (HART) to retrieve any diagnostics and take appropriate action.
3. Cycle the power to the transmitter. This executes initialization checks on RAM and ROM.
4. Use the ST80 Series configuration tool to perform a ROM CRC check.
5. Use digital communications (configuration tool) to retrieve any diagnostics and take appropriate action.
6. Perform a two-point calibration of the transmitter over the full working range. If this is performed with only electrical instrumentation, this proof test will not detect any failures of the sensor that were undetected by internal diagnostics.
7. Remove the bypass and otherwise restore normal operation.

Calculation of Average Probability Of Failure On Demand (PFD_{avg})

PFD_{avg} calculation can be determined by the owner/operator of a process using the failure rate data shown in [Table 1](#) below. Contact FCI for a copy of the FMEDA report.

Product Repair

The ST80 Series is repairable by major component replacement. All product repair and part replacement is to be performed by qualified personnel only.

ST80 Series SIS Reference

The ST80 Series must be operated in accordance to the functional and performance specifications listed in the IO&M (Document No. 06EN003490) Technical Specifications section.

Failure Rate Data

The FMEDA report includes failure rates and common cause Beta factor estimates (contact FCI for a copy of the report). [Table 1](#) below summarizes the failure rate data.

Table 1 – Failure Rates with Good Maintenance Assumptions in FIT @ SSI=2 According to IEC 61508

Device – ST80/ST80L	SFF	λ_{DU}	λ_{DD}	λ_{SU}
HART Output, AC Power Supply	79.8%	583	1386	784
HART Output, DC Power Supply	77.2%	555	1145	735
Analog Output 2, AC Power Supply	78.3%	557	1253	761
Analog Output 2, DC Power Supply	77.1%	529	1011	712

Terminology

SFF = Safe Failure Fraction

λ_{DU} = Failure rate dangerous undetected faults

λ_{DD} = Failure rate dangerous detected faults

λ_{SU} = Failure rate safe undetected faults

FIT= Failure rate in 10⁻⁹/hour

Proof Test Coverage

Based on the Proof Test procedures recommended in this document [Table 2](#) below shows the Total Coverage of the device based on the remaining Dangerous Undetected failures not accounted for by either the Proof Test or Internal Diagnostics (Dangerous Detected).

Table 2 – Total Coverage (Proof Test DD + Internal Diagnostics DD)

Device – ST80/ST80L	SFF	Proof Test Coverage	λ_{DUPT} (FIT)	Total Coverage
HART Output, AC Power Supply	79.8%	66%	385	93.8%
HART Output, DC Power Supply	77.2%	65%	361	92.0%
Analog Output 2, AC Power Supply	78.3%	67%	373	92.8%
Analog Output 2, DC Power Supply	77.1%	65%	344	92.4%



*Flow & Level Instrumentation
Solutions for Industrial Processes*

**FCI's Complete Customer Commitment. Worldwide
ISO 9001 and AS9100 Certified**

Visit FCI on the Worldwide Web: www.fluidcomponents.com

FCI World Headquarters

1755 La Costa Meadows Drive | San Marcos, California 92078 USA | Phone: 760-744-6950 Toll Free (US): 800-854-1993 Fax: 760-736-6250

FCI Europe

Persephonestraat 3-01 | 5047 TT Tilburg, The Netherlands | Phone: 31-13-5159989 Fax: 31-13-5799036

FCI Measurement and Control Technology (Beijing) Co., LTD | www.fluidcomponents.cn

Room 107, Xianfeng Building II, No.7 Kaituo Road, Shangdi IT Industry Base, Haidian District | Beijing 100085, P. R. China
Phone: 86-10-82782381 Fax: 86-10-58851152

Notice of Proprietary Rights

This document contains confidential technical data, including trade secrets and proprietary information which is the property of Fluid Components International LLC (FCI). Disclosure of this data to you is expressly conditioned upon your assent that its use is limited to use within your company only (and does not include manufacture or processing uses). Any other use is strictly prohibited without the prior written consent of FCI.