



## Using the HART 275 Communicator with ST98 Series

---

**Universal Commands** (commands 0-33) can be accessed with no additional programming of the Customer's 275 Communicator.

(This means that they can read, Flow Rate, Temperature and Totalizer values)

**FCI Specific Commands** (commands 128 and above) require that the Communicator be sent to a HART Foundation Programming Center to have it programmed for the FCI specific commands. As of December 1, 2002, Hart Programming Centers will be capable of programming the Communicator to allow it to access all commands.

(This will allow the user to access all diagnostic & test functions available in the ST98.)

To find the Programming Center nearest the user, access the Hart Foundation Web site. The Programming Center will charge approximately \$200 to program the unit.