

Supplemental Manual

ST100A Series Safety Instrumented System (SIS) Requirements



Notice of Proprietary Rights

This document is the property of Fluid Components International LLC (FCI) and contains confidential and proprietary information including, without limitation, trade secrets, design, manufacturing, processing, form fit and function data, technical data, and/or cost and pricing information, developed exclusively at FCI's private expense. Disclosure of this information to you is expressly conditioned on your assent that its use is limited to use only within your company (and does not include manufacturing or processing uses). Any other use, including re-procurement, replication of FCI products, or other use directly or indirectly in any way detrimental to FCI's interests is strictly prohibited without prior written consent of FCI. This document is subject to the protections of 18USC1905 (Trade Secrets Act), 5USC552 (Freedom of Information Act), Executive Order 12600 of 6/23/87, 18USC1832 (Economic Espionage and Trade Secrets Act of 1996), and Cal. Civ. Code 3426 et seq (Uniform California Trade Secrets Act). Recipients of this document agree to maintain this legend and affix it to any duplication or reproduction, in whole or in part, of the document.

© Copyright 2024 by Fluid Components International LLC. All rights reserved. FCI is a registered trademark of Fluid Components International LLC. Information subject to change without notice.

Table of Contents

Table of Contents.....	iii
List of Tables.....	iii
ST100A Series Safety Instrumented System (SIS) Requirements	1
Introduction	1
Compliance Through FMEDA (Failure Modes, Effects and Diagnostic Analysis).....	1
ST100A Safety Identification.....	1
Installation in SIS Applications	1
Configuring the Instrument for SIS Application	1
Proof Test.....	2
Recommended Proof Test	2
Product Repair	2
ST100A Series Safety Instrumented System (SIS) Reference.....	2
Failure Rate Data	2
Proof Test Coverage.....	3

List of Tables

Table 1 – Failure Rates According to IEC 61508-1	2
Table 2 – Proof Test Coverage — Static Applications ST100A Series.....	3

This Page Intentionally Left Blank

ST100A Series Safety Instrumented System (SIS) Requirements

Introduction

This document describes how to configure the ST100A Series for IEC 61508 compliance in a Safety Instrumented System (SIS) application. The safety-critical output of the ST100A Series is provided through the Channel #1 4-20 mA analog output.

Compliance Through FMEDA (Failure Modes, Effects and Diagnostic Analysis)

Safety Integrity Level, Hardware Fault Tolerance:

- SIL 1, HFT = 0
- SIL 2, HFT = 1

Subsystem Type:

- B

ST100A Safety Identification

Verify that the ST100A Series is using firmware version 2.04L or higher. The firmware version can be identified via the HMI (models with Display), the ST100A configuration software or by contacting FCI directly to cross reference the unit's serial number with its firmware version as shipped. The information in this document relates to all ST100A Series flow meter configurations.

Installation in SIS Applications

Installations are to be performed by qualified personnel. No special installation is required in addition to the standard installation practices outlined in the ST100A Series IO&M (Document No. 06EN003480). Environmental and operational limits are listed in the manual's Technical Specification section.

Configuring the Instrument for SIS Application

For all safety-related applications, configure the ST100A Series flow meter in a fail-safe alarm configuration as listed below.

- Verify that materials are compatible with process conditions.
- Configure the device for fault indication per NAMUR NE43 OR the logic solver is configured to interpret 4 mA as a fault condition.
 - Low Alarm current is ≤ 3.6 mA
 - High Alarm current is ≥ 21.0 mA
 - Channel #1 4-20 mA analog output is configured for Flow
- The safety accuracy of the ST100A Series mass flow output is $\pm 0.75\%$ of reading and $\pm 0.5\%$ of full scale. Base accuracy is dependent on the process gas composition, pressure and temperature. These parameters can be found in the appropriate calibration certificate. Contact FCI if you would like to obtain a copy referenced by the unit's serial number.
- Use the password protection feature of the ST100A firmware to prevent accidental or deliberate change of process parameters and configuration data during normal operation.
- HART protocol is only used for setup, calibration, and diagnostic purposes; not for safety critical operation.

Proof Test

Use the recommended proof test described below to identify Dangerous Undetected faults in the ST100A Series thermal mass flow meter. This test consists of cycling the power, setting the output to minimum and maximum values, and performing a calibration check. It is recommended that the proof test be performed annually at a minimum.

Recommended Proof Test

1. Bypass the safety function and take appropriate action to avoid a false trip.
2. Use digital communications (HART) or software configuration to retrieve any diagnostics and take appropriate action.
3. Cycle the power to the transmitter. This executes initialization checks on RAM and ROM and clears any soft errors.
4. Send a HART command to the transmitter to go to the high alarm current output and verify that the analog current reaches that value¹.
5. Send a HART command to the transmitter to go to the low alarm current output and verify that the analog current reaches that value².
6. Inspect the transmitter for any leaks, visible damage, or contamination.
7. Perform a two-point calibration³ of the transmitter over the full working range.
8. Remove the bypass and otherwise restore normal operation.

- Notes:
1. This tests for compliance voltage problems such as a low loop power supply or increased wiring resistance. This also tests for other possible failures.
 2. This tests for possible quiescent current related failures.
 3. If the two-point calibration is performed with electrical instrumentation, this proof test will not detect any failures of the sensor.

Product Repair

The ST100A Series is repairable by major component replacement. All product repair and part replacement is to be performed by qualified personnel only.

ST100A Series Safety Instrumented System (SIS) Reference

The ST100A Series must be operated in accordance with the functional and performance specifications listed in the IO&M (Document No. 06EN003480) Technical Specification section.

Failure Rate Data

The FMEDA report includes failure rates and common cause Beta factor estimates (contact FCI for a copy of the report). [Table 1](#) below summarizes the failure rate data (Good Maintenance Assumptions in FIT @ SSI = 2).

Table 1 – Failure Rates According to IEC 61508-1

Device	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}	#	SFF
Single Probe AC	0	806	1479	632	2098	78.3 %
Single Probe DC	0	757	1237	604	2105	76.8 %
Dual Probe AC	0	821	1909	610	1739	81.7 %
Dual Probe DC	0	773	1668	582	1747	80.7 %

Where:

- λ_{SD} = Fail Safe Detected
- λ_{SU} = Fail Safe Undetected
- λ_{DD} = Fail Dangerous Detected
- λ_{DU} = Fail Dangerous Undetected
- # = No Effect Failures
- SFF = Safe Failure Fraction
- FIT = Failure rate in 10^{-9} /hour

Proof Test Coverage

The Proof Test Coverage for the various product configurations is given in [Table 2](#).

Table 2 – Proof Test Coverage — Static Applications ST100A Series

Device	λ_{DuPT} (FIT)	Proof Test Coverage
Single Probe AC	196	69%
Single Probe DC	195	68%
Dual Probe AC	211	66%
Dual Probe DC	210	64%



*Flow & Level Instrumentation
Solutions for Industrial Processes*

**FCI's Quality Management System is
ISO 9001 and AS9100 Certified**

Visit FCI online at www.fluidcomponents.com

FCI World Headquarters

1755 La Costa Meadows Drive | San Marcos, California 92078 USA | Phone: 760-744-6950 Toll Free (US): 800-854-1993

FCI Europe

Persephonestraat 3-01 | 5047 TT Tilburg, The Netherlands | Phone: 31-13-5159989 Fax: 31-13-5799036

FCI Measurement and Control Technology (Beijing) Co., LTD | www.fluidcomponents.cn

Room 107, Xianfeng Building II, No.7 Kaituo Road, Shangdi IT Industry Base, Haidian District | Beijing 100085, P. R. China
Phone: 86-10-82782381 Fax: 86-10-58851152

Notice of Proprietary Rights

This document is the property of Fluid Components International LLC (FCI) and contains confidential and proprietary information including, without limitation, trade secrets, design, manufacturing, processing, form fit and function data, technical data, and/or cost and pricing information, developed exclusively at FCI's private expense. Disclosure of this information to you is expressly conditioned on your assent that its use is limited to use only within your company (and does not include manufacturing or processing uses). Any other use, including re-procurement, replication of FCI products, or other use directly or indirectly in any way detrimental to FCI's interests is strictly prohibited without prior written consent of FCI. This document is subject to the protections of 18USC1905 (Trade Secrets Act), 5USC552 (Freedom of Information Act), Executive Order 12600 of 6/23/87, 18USC1832 (Economic Espionage and Trade Secrets Act of 1996), and Cal. Civ. Code 3426 et seq (Uniform California Trade Secrets Act). Recipients of this document agree to maintain this legend and affix it to any duplication or reproduction, in whole or in part, of the document.